


American Public Works Association (APWA) Standard Plan No. 111-2 has been modified by the City of Cypress with conditions as noted below:

APWA #	MODIFIED BY	
	CITY OF CYPRESS #	NAME
111-2	111-2-CYP	CURB RAMP

CONDITIONS

1. The level landing at the upper end of the ramp shall have a minimum depth of 48", and shall extend the full width of the ramp.
2. Sidewalks shall have a minimum width of 48".
3. Ramp slope shall not exceed 8.33%. Flared side slopes to ramps shall not exceed 10%.
4. Transitions at top and bottom of ramps shall be flush and free of abrupt changes.
5. When provided at a marked crossing, the ramp shall terminate within the markings, or existing markings shall be adjusted as necessary per the approval of the City Engineer.

▲		
Rev.	Approved	Date

<b>CITY OF CYPRESS</b> DEPARTMENT OF PUBLIC WORKS ENGINEERING DIVISION	<h2 style="margin: 0;">CURB RAMP</h2>
APP  <u>12/13/99</u> <small>Director of Public Works</small> <span style="float: right;"><small>Date</small></span>	STD. PLAN NO. <b>111-2-CYP</b>